



WESTCHESTER COUNTY DEPARTMENT OF HEALTH
POLICY STATEMENT

As of April 4, 2023, the following information shall be provided on all applications and As-Built plans for Construction Compliance Approval:

For applications approved with the installation of a new well:

A well detail showing the following minimum information on the As-Built plans:

- The depth and size of the well casing
- The total depth of the drilled well
- A minimum of 18-inches of well casing extending above the final ground surface with top soil or grade pitched away from casing to final ground surface
- Well pump make and model

For applications that included a pump chamber with sewage pump(s):

- The make and model of the pump(s) installed.

Applications for Construction Compliance Approval submitted without the above information will not be approved. The Construction Compliance Checklist on the Westchester County Department of Health website has been revised to include the above additions.

Should you have any questions, please contact the Mt. Kisco Office at 914-864-7333.