

GASOLINE DISPENSING SITES DAILY INSPECTION LOG

PBS No.: _____

Month/Year: _____

Inspect vapor collection system equipment daily. If problems are found, the dispenser must be taken out of service until repair is complete. Stage I: Fill caps must have gaskets and seal without spinning. Poppets must spring back when depressed. Coaxial drop tubes must be installed no more than 3" below top of fill port. Hoses: Check for kinks, holes, tears, flat spots, worn areas. Check for leaks in breakaways or swivels. Retractors must be kept in good working order. Hoses cannot contact pad or island. Nozzles: Check for holes or tears in boots, faceplates, flexible cones.

Day	Inspector	Stage I		Stage II Hoses		Stage II Nozzles	
		OK	Problems found and action taken	OK	Problems found and action taken	OK	Problems found and action taken
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							