

ABOVEGROUND TANK INSPECTION

PBS No.:	PBS No.:		
----------	----------	--	--

Visually inspect tanks and piping at least once per month. The tank and any remote product level gauge must be labeled with the tank ID, design capacity, working capacity and product stored. Inspect exterior surfaces of tank, pipes, valves and other equipment for leaks or maintenance deficiencies. Identify any cracks, areas of wear, corrosion, thinning, excessive settlement of structures, separation or swelling of tank insulation, structural or foundation weaknesses, malfunctioning equipment, poor maintenance or operating practices. Verify that the overfill prevention device is operational. Verify integrity of leak detection and corrosion protection systems. Document any problems and corrective action or repairs. Maintain inspection reports for at least 10 years. Notify WCDH at 914-813-5000 and NYSDEC at 800-457-7362 of any known or suspected product releases.

Date Inspector	Tank ID(s) Labeling	Exterior Surfaces	Overfill Prevention	Double-Walled Tank		
						Interstitial Space